

**ERRATA SHEET FOR ANSI/ASHRAE STANDARD 15-2024,
Safety Standard for Refrigeration Systems**

January 2, 2025

The corrections listed in this errata sheet apply to ANSI/ASHRAE Standard 15-2024. The outside back cover marking identifying the first printing is “Product code: 86938”

(Note: Additions are shown in underline and deletions are shown in ~~striketrough~~.)

<u>Page</u>	<u>Erratum</u>
--------------------	-----------------------

22	7.6.4* Mechanical Ventilation. [...]
-----------	---

a. Mechanical ventilation *shall* be provided that will remove leaked *refrigerant* from the space where *refrigerant* leaking from the *refrigeration system* is expected to accumulate. The space *shall* be provided with an exhaust or transfer fan. Fans used to exhaust air ~~exhaust air~~ from the space or transfer air to a separate indoor space *shall* comply with Equation 7-10:

46	Informative Note: Tables 9-1 through 9-6 are based on $H = 150 \text{ Btu}/(\text{ft}^2 \cdot \text{min})$ [<u>28.4</u> kW/m ²]. As stated in Section 9.7.5.4, the <i>relieving pressures</i> are based on the <i>pressure relief device set pressure</i> is equal to <i>design pressure</i> .
-----------	--

56	9.13.6.1 Leak Testing Protocol. [...] A vacuum of 0.009 <u>6</u> 7 psi (<u>66.7</u> Pa) absolute or lower <i>shall</i> be achieved (0.0197 in. of mercury [32°F]; 500 μm of mercury [0°C]; 500 μm).
-----------	---